## Speed-O-Controls Pvt. Ltd.

C-15/16, Nand-Jyot Industrial Estate. Tel. No. : 022-42469700-99

Andheri-Kurla Road, Mumbai-400072 Fax

Website: www.speedocontrols.com

: 022-28518516

: sales@socgroup.in

## TEST CERTIFICATE/GUARANTEE CERTIFICATE

**Email** 

: J0477 - JINDAL ALUMINIUMLIMITED **CUSTOMER** 

P. ORDER NO: P0230301573

DATE: 07/03/2023

JOB NO

: MQC000004443

Sr. No Model No. Description of the Material(s) LS/2SH/2

Two Way Lever Type Shunt Limit Switch with (2 NC) Contact. Contacts rated for 10 Amps rated at 500

V.A.C.

ITEM CODE:07010299 SR.NO.:LQ-2798/2799

Serial No.

**OPERATION CHECK SATISFACTORY** 

INSULATION RESISTANCE Above 50 Megaohms

HIGH VOLTAGE TEST 2000 Volts for 1 minute OK

## **WARRANTY DECLARATION:**

We hereby guarantee to replace free of cost EX-works Mumbai any components found defective due to bad workmanship or faulty raw material, provided the defect are not due to damage in the transit, bad

RI