


P-6751

12114



ELECTRIC CONDUCTIVITY = 55% MIN IACS



SYMBOL OF QUALITY  
AN ISO 9001 COMPANY

**JINDAL ALUMINIUM LTD.**  
*BANGALORE-560073 (INDIA)*

	NAME	DATE
DRAWN	RAGHAVENDRA	14-10-2006
CHECKED		
APPROVED		
SCALE		1:1
AREA mm <sup>2</sup>		1192.274
PERIMETER mm.		218.85
WEIGHT kg/m		3.219
DRAWING No.		SECTION No.
P-6751		-
12114		12114

1. ALL DIMENSIONS ARE IN mm.
2. ROUND OFF ALL SHARP CORNERS WITH 0.40 mm.
3. TOLERANCES WILL BE AS PER BS:2898-1980 UNLESS OTHERWISE SPECIFIED

PARTY'S NAME	AL-AHLEIA SWITCHGEAR CO. KSCC, KUWAIT
PARTY'S DRAWING No.	AS PER SPECIFICATION
ALLOY & TEMPER	6101 T6
DESCRIPTION	FLAT BAR WITH 3mm CORNER RADIUS