



P-19663-1

X2541



 SYMBOL OF QUALITY AN ISO 9001 COMPANY	JINDAL ALUMINIUM LTD. BANGALORE-560073 (INDIA)	NAME	DATE
		DRAWN J.P.KAUSHIK	21-06-2019
1. ALL DIMENSIONS ARE IN mm. 2. ROUND OFF ALL SHARP CORNERS WITH 0.40 mm. 3. TOLERANCES WILL BE AS PER IS:3965-1981 UNLESS OTHERWISE SPECIFIED		CHECKED	
		APPROVED B.NATARAJA	05-07-2019
PARTY'S NAME CROWN ELECTRIC ENGINEERING & MANUFACTURING LLC, USA		SCALE	1:1
		AREA mm ²	8222.579
PARTY'S DRAWING No. AS PER DRAWING		PERIMETER mm.	1320.312
		WEIGHT kg/m	22.201
ALLOY & TEMPER 1350 F		DRAWING No.	SECTION No.
		P-19663-1	-
DESCRIPTION MISC. TUBE-BUS DUCT CONDUCTOR H-36(7500 AMP)		X2541	X2541